Advanced PID Loop Tuning and Control Strategies Course

21 – 25 February 2027
Johannesburg

AGILE LEADERS
Training Center

AGILE LEADERS
Training Center

Advanced PID Loop Tuning and Control Strategies Course

Ref: 947_172310 **Date:** 21 – 25 February 2027 **Location:** Johannesburg **Fees:** 6000 Euro

Overview

Advanced PID Loop Tuning and Control Strategies Course is a 1-week course for control, instrumentation, process, automation, and operations support professionals who leave with a PID Loop Performance and Strategy Portfolio. Participants use dynamic response evidence, process models, PID tuning, loop interaction analysis, cascade control, feedforward control, constraint handling, and performance monitoring to correct unstable or inefficient behavior. The course replaces trial-and-error adjustments with traceable engineering decisions. Agile Leaders Training Center provides this course on advanced PID loop tuning and control strategies.

Who Should Attend

- Teams responsible for control-loop design, tuning, and performance.
- Functions responsible for instrumentation reliability and final control elements.
- Groups responsible for process dynamics and operating constraint analysis.
- Automation teams responsible for controller configuration and control narratives.
- Operations support functions responsible for disturbance response and stability.

The course assumes participants can interpret process trends and basic PID behavior, and leaves out introductory process measurement and controller programming.

Departments and Industries

The course supports control-performance decisions across continuous and batch operations.

- Process control and industrial automation
- Instrumentation and maintenance engineering
- Oil, gas, chemical, and refining operations
- Power, water, and utilities operations
- Food, pharmaceutical, and manufacturing processes

Learning Objectives

By the end of this course, participants will be able to:

- Analyze process dynamics from step-response evidence.
- Apply PID and IMC/Lambda tuning methods.
- Diagnose valve, measurement, saturation, and interaction problems.
- Compare cascade, feedforward, ratio, and override structures.
- Evaluate loop performance using trend-based indicators.
- Build a retuning and advanced-strategy implementation plan.

AGILE LEADERS
Training Center

Course Agenda

Day 1: Dynamic Response Evidence

- Control Loop Functional and Signal-Path Map
- Open-Loop Step-Test Planning Checklist
- Process Gain, Time Constant, and Dead-Time Worksheet
- First-Order-Plus-Dead-Time Model Fitting Method
- Disturbance and Setpoint Response Evidence Record

Day 2: PID Tuning Decisions

- Proportional, Integral, and Derivative Action Matrix
- IMC/Lambda Closed-Loop Response Method
- Robustness and Performance Tradeoff Chart
- Anti-Windup and Output Constraint Configuration
- Tuning Method Comparison and Selection Sheet

AGILE LEADERS
Training Center

Day 3: Loop Diagnostics

- Valve Stiction and Deadband Diagnostic Pattern
- Measurement Noise and Filtering Decision Guide
- Controller Saturation and Constraint Evidence Log
- Oscillation Source Isolation Tree
- Loop Performance Monitoring Dashboard

Day 4: Advanced Control Strategies

- Cascade Master-Slave Timing Design Map
- Feedforward Disturbance Model and Bias Structure
- Ratio Control Scaling and Tracking Worksheet
- Override and Selective Control Constraint Matrix
- Loop Interaction and Decoupling Assessment

Day 5: Integrated Tuning Practice

- Suggested Exercise: Step-Test Evidence and Model Fitting
- Suggested Exercise: PID and IMC/Lambda Tuning Comparison
- Suggested Exercise: Oscillation and Valve Fault Diagnosis
- Suggested Exercise: Cascade and Feedforward Strategy Selection
- Capstone Exercise: PID Loop Performance and Strategy Portfolio

Practical Exercises

The course uses suggested activities to connect evidence, tuning, diagnostics, and strategy decisions.

- Suggested activity: fit a dynamic model from a process trend and document model confidence.
- Suggested activity: compare tuning settings against robustness, response, and actuator movement criteria.
- Suggested activity: separate tuning symptoms from valve, measurement, and constraint faults.
- Suggested activity: select an advanced control structure for a defined disturbance path.

FAQs

Who suits advanced PID loop tuning and what does it assume?

Control, instrumentation, process, automation, and operations support professionals suit the course. It assumes participants can read process trends and recognize basic PID behavior, while introductory measurement and controller programming remain outside scope.

How does advanced PID loop tuning differ from introductory process control training?

Advanced PID loop tuning uses measured dynamics, model-based tuning, interaction analysis, constraint diagnosis, and strategy selection rather than concentrating on basic feedback concepts and controller terminology.

How are PID settings selected from process response evidence?

PID settings are selected by estimating process gain, time constant, and dead time, choosing a response objective, applying a suitable tuning method, and checking robustness, disturbance rejection, actuator movement, and operating constraints.

When should cascade control or feedforward control be used?

Cascade control suits a measurable secondary variable that responds faster than the primary loop. Feedforward control suits a measurable disturbance whose effect can be modeled and corrected before the controlled variable departs from target.

Why does a tuned PID loop still oscillate?

A tuned PID loop may still oscillate because of valve stiction, deadband, measurement noise, saturation, interacting loops, changing process dynamics, or logic outside the controller. Diagnosis separates these causes before retuning.

Conclusion

Participants take back a PID Loop Performance and Strategy Portfolio linking response evidence, model parameters, tuning choices, diagnostic findings, and advanced-control decisions. The portfolio gives engineering and operations teams a shared basis for retuning and review. It replaces undocumented adjustments with a repeatable control-performance workflow.